

# Engineer's Letter of Assurance : WELL WELL v2, Q3-Q4 2024

## Instructions

WELL Certification is determined by onsite Performance Verification and documentation, including Letters of Assurance from the appropriate professionals overseeing the implementation of a specific WELL feature and component parts during design, construction or operations. The template should be completed, signed and submitted as part of the documentation package.

- 1. Place a checkmark at every part completed and leave blank those that are not being pursued or being completed by another team member.
- 2. Initial every feature completed and leave blank those that are not being pursued or being completed by another team member.
- 3. Sign and date at the bottom of this letter.

If an individual other than the Engineer is responsible for any of the requirements contained in this Letter of Assurance, he/she is permitted to sign off on the respective requirements but must complete a separate Letter of Assurance for those specific requirements. This individual should submit a different copy of this form and check the boxes as it pertains to his/her own responsibility. On his/her own Letter of Assurance form(s), this individual should sign and complete the final page and include a description of his/her role on the project next to his/her signature.

The scope of this letter of assurance is as follows (please initial):

Intent stage  
(for Precertification only)

☐

The information contained in this document is accurate as of current designs and anticipated project operations.

Implementation stage  
(for Precertification or WELL Certification)

☐

This document is prepared in relation to final construction documents and/or implemented operations and policies.

Check	Air	Initials
	A01 Air Quality	<input type="checkbox"/>

This project is designed to meet the parts selected below:

### Part 4: Meet Thresholds for Radon

*All Spaces:*

*Mechanical ventilation*

For regularly occupied spaces at or below grade, the following requirement is met:

☐

- a. All regularly occupied spaces at or below grade meet Feature A03, Part 1, Option 1.

	A03 Ventilation Design	<input type="checkbox"/>
--	------------------------	--------------------------

This project is designed to meet the parts selected below:

### Part 1: Ensure Adequate Ventilation

*All Spaces:*

### *Mechanically ventilated spaces*

For mechanically ventilated buildings, one of the following requirements is met:

☐ a. Newly installed ventilation systems are designed to meet the supply and exhaust rates set in one or more of the following ventilation guidelines, which must describe ventilation rates for at least 90% of the project area. The ventilation system is scheduled to be tested and balanced after project occupancy:

1. ASHRAE 62.1-2010 or any more recent versions (Ventilation Rate Procedure or IAQ Procedure).<sup>12</sup>
2. ASHRAE 62.2-2016.<sup>13</sup>
3. EN 16798-1.<sup>14</sup>
4. AS 1668.2-2012 or any more recent version.<sup>15</sup>
5. CIBSE Guide A: Environmental Design, version 2007 or any more recent version.<sup>16</sup>

☐ b. Existing ventilation systems have been tested and balanced to meet supply and exhaust rates set in one or more ventilation guidelines listed above within the last five years.

OR-----

### *AND Naturally ventilated spaces*

For naturally ventilated buildings with no mechanical ventilation, the following requirements are met:

☐ a. One or more of the following design criteria, which must describe ventilation rates for at least 90% of the project area:

1. Natural Ventilation Procedure in ASHRAE 62.1-2010 or any more recent version.<sup>12</sup>
2. CIBSE AM10: Natural Ventilation in Non-Domestic Buildings (2005 or any more recent version) Section 2.4 – Natural ventilation strategies and Chapter 4 – Design Calculations.<sup>17</sup>
3. AS 1668.4-2012 or any more recent version.<sup>15</sup>
4. Any reference in Option 1, which describes natural ventilation procedures.

☐ b. Vents and windows used to meet the ventilation requirements in one of the standards mentioned above are permanently open or have controls to prevent their closure during periods of occupancy. (Operable windows not used in ventilation calculations may be user operated.)

☐ c. Outdoor air meets the following thresholds as an average for the previous year:

1. PM<sub>2.5</sub> less than 15 µg/m<sup>3</sup>.<sup>18</sup>
2. PM<sub>10</sub> less than 30 µg/m<sup>3</sup>.<sup>18</sup>

OR-----

### *AND Naturally ventilated spaces in areas with elevated particulate matter*

For naturally ventilated buildings with no mechanical ventilation, the following requirements are met:

☐

- a. One or more of the following design criteria, which must describe ventilation rates for at least 90% of the project area:
1. Natural Ventilation Procedure in ASHRAE 62.1-2010 or any more recent version.<sup>12</sup>
  2. CIBSE AM10: Natural Ventilation in Non-Domestic Buildings (2005 or any more recent version) Section 2.4 – Natural ventilation strategies and Chapter 4 – Design Calculations.<sup>17</sup>
  3. AS 1668.4-2012 or any more recent version.<sup>15</sup>
  4. Any reference in Option 1, which describes natural ventilation procedures.

☐

b. Vents and windows used to meet the ventilation requirements in one of the standards mentioned above are permanently open or have controls to prevent their closure during periods of occupancy. (Operable windows not used in ventilation calculations may be user operated.)

☐

- c. Outdoor air meets the following thresholds as an average for the previous year:
1. PM<sub>2.5</sub> less than 35 µg/m<sup>3</sup>.<sup>18</sup>
  2. PM<sub>10</sub> less than 70 µg/m<sup>3</sup>.<sup>18</sup>

A06 Enhanced Ventilation Design

☐

This project is designed to meet the parts selected below:

Part 1: Increase Outdoor Air Supply

*All Spaces:*

*Increased air supply*

For mechanically ventilated buildings, the following requirement is met in all occupiable spaces:

☐

- a. Exceed outdoor air supply rates described in one of the ventilation guidelines listed in Feature A03 Part 1 by the percentages shown in the table below:

Tier	Thresholds	Points
1	30%	1
2	60%	2

OR-----

*AND Demand control ventilation*

For mechanically ventilated buildings, the following requirements are met in at least 90% of regularly occupied spaces:

☐

a. A demand-controlled ventilation (DCV) system regulates the outdoor air ventilation rate to keep CO<sub>2</sub> levels less than the thresholds specified in the table below, at the maximum intended occupancy:

Tier	Threshold		Threshold	Points
1	900 ppm	OR	500 ppm above outdoor levels	1
2	750 ppm	OR	350 ppm above outdoor levels	2

☐

b. Carbon dioxide is measured at the return air diffusers or in the breathing zone at least 3.3 ft away from doors, windows, air supply diffusers or occupants. At least one sensor is used for each occupancy zone (or per air handling unit, if a single zone is served by multiple air handling units). If the occupancy density/pattern/usage is substantially different in two adjacent areas, each area must be considered a separate zone.

Part 2: Improve Ventilation Effectiveness

All Spaces:

Displacement ventilation system

The project uses a displacement ventilation system in at least 90% of regularly occupied spaces, with one of the following as a basis for design:

☐

a. ASHRAE Guidelines RP-949.<sup>9</sup>

☐

b. ASHRAE 62.1-2019, "Stratified Air Distribution Systems (Section 6.2.1.2.1).<sup>10</sup>

☐

c. REHVA Guidebook No. 01 (Displacement Ventilation in non-industrial premises).<sup>11</sup>

OR-----

AND Personalized ventilation system

At least 50% of workstations incorporate personalized ventilation systems that meet the following requirements:

☐

- a. One of the following strategies is implemented to efficiently deliver air to occupants:
- 1. Outdoor air is supplied in the breathing zone through vents incorporated into or mounted on furniture, and the return air diffusers within the space are located at least 9 ft above the floor.<sup>10</sup>
  - 2. The system's zone air distribution effectiveness (E<sub>z</sub>) is at least 1.20.<sup>10</sup>

☐

- b. One of the following strategies is implemented to support thermal comfort:
- 1. Outdoor air is supplied with an air speed of no greater than 50 fpm at the occupant's head.<sup>10</sup>
  - 2. The air speed from each outdoor air supply vent is individually controllable by occupants through a controller within the space, a mobile application or website.

A07 Operable Windows

☐

This project is designed to meet the parts selected below:

Part 2: Manage Window Use

All Spaces:

### *Window operation*

Indicator lights and/or digital displays at windows (at least one per room with windows) cue occupants when conditions outside are suitable for opening windows:

- ☐ a. PM<sub>2.5</sub>: 15 µg/m<sup>3</sup> or lower.
- ☐ b. Dry-bulb temperature: within 15 °F of indoor air temperature setpoint.
- ☐ c. Relative Humidity: 65% or lower.

## A08 Air Quality Monitoring and Awareness

☐

This project is designed to meet the parts selected below:

### **Part 1: Install Indoor Air Monitors**

#### *All Spaces except Dwelling Units & Guest Rooms:*

##### *Sensor requirements*

The project deploys monitors with sensors that measure at least three of the following parameters in occupiable spaces in compliance with the requirements outlined in the Continuous Monitoring Protocols of the Performance Verification Guidebook:

- ☐ a. PM<sub>2.5</sub> or PM<sub>10</sub>.
- ☐ b. Carbon dioxide.
- ☐ c. Carbon monoxide.
- ☐ d. Ozone.
- ☐ e. Nitrogen dioxide.
- ☐ f. Total VOCs.
- ☐ g. Formaldehyde.

#### *Dwelling Units & Guest Rooms:*

##### *Sensor requirements*

The project deploys monitors with sensors that measure at least three of the following parameters in occupiable spaces in compliance with the requirements outlined in the Continuous Monitoring Protocols of the Performance Verification Guidebook:

- ☐ a. PM<sub>2.5</sub> or PM<sub>10</sub>.
- ☐ b. Carbon dioxide.
- ☐ c. Carbon monoxide.

☐

d. Ozone.

☐

e. Nitrogen dioxide.

☐

f. Total VOCs.

☐

g. Formaldehyde.

## A10 Combustion Minimization

☐

This project is designed to meet the parts selected below:

### Part 1: Manage Combustion

*All Spaces except Commercial Kitchen Spaces:*

*Low-emission combustion sources*

Equipment used by the project for heating, cooling, water heating, process heating or power generation (including back-up, if used for more than 200 hours per year) meets one or more of the following requirements:

☐

a. Comply with California's South Coast Air Quality Management District emission rules for pollution.<sup>7</sup>

☐

b. Are electric.

☐

c. Are supplied by district heating or cooling.

## A11 Source Separation

☐

This project is designed to meet the parts selected below:

### Part 1: Manage Pollution and Exhaust

*Commercial Kitchen Spaces:*

*Control cooking pollution*

The following requirements are met:

☐

a. Canopy hoods have side or partial panels, when allowable by code.<sup>11</sup>

☐

b. Type II hood overhangs and setbacks comply with ASHRAE 154-2011.<sup>12</sup>

☐

c. The vertical distance between the front lower lip of the hood and the cooking surface is less than or equal to 4 ft.<sup>12</sup>

☐

d. Replacement air velocity near (or directed at) the hood is less than 75 fpm.<sup>11</sup>

☐

e. Replacement air introduced directly into the exhaust hood cavity does not exceed 10% of the hood exhaust airflow rate.<sup>13</sup>

☐

f. Appliances are grouped under exhaust hoods according to effluent production and associated ventilation requirements, as specified in ASHRAE 154-2011, per hood type (defined by the classifications used in ASHRAE 154-2011 for light, medium, heavy and extra-heavy appliance duty levels).<sup>12</sup>

☐

g. Appliances have a rear seal between the appliance and the wall, when allowable by code.<sup>15</sup>

☐

h. Appliances located at the end of a cook line requiring exhaust airflow rates greater than 300 cfm/ft have a full side panel or an end wall.<sup>12</sup>

OR-----

*AND No applicable commercial appliances*

The following requirements are met:

☐

a. There are no appliances that require a hood, as specified in ASHRAE 154-2011 (Table 2 - Type I Hood Requirements by Appliance Type, Table 2 - Type II Hood Requirements by Appliance Description).<sup>12</sup>

*Dwelling Units & Guest Rooms:*

The following requirements are met:

☐

a. Where cooking burners and stove top cooking appliances are present, a range hood meets the following:

1. Exhaust air is vented directly to the outdoors.<sup>16</sup>
2. Exhaust air outlets are separated from any air intakes by at least 10 ft, unless otherwise specified by local code.<sup>17</sup>
3. The minimum operating exhaust airflow rate is the greater of 100 cfm per linear foot of range hood width or 200 cfm.<sup>18</sup>
4. The range hood device, when in operation, covers at least 75% of the burner area.<sup>19</sup>

☐

b. All bathrooms contain one of the following:

1. Exhaust fan.
2. Operable window.

## A12 Air Filtration

☐

This project is designed to meet the parts selected below:

### Part 1: Implement Particle Filtration

*All Spaces:*

*Filtration levels*

The following requirement is met:

☐

a. Media filters are used in the ventilation system to filter outdoor air supplied to the space, in accordance with thresholds specified in the table below:<sup>5,6</sup>

Annual Average Outdoor PM <sub>2.5</sub> Threshold	Average Air Filtration Efficiency (particles 0.3-1 µm)
23 µg/m <sup>3</sup> or less	≥ 35% (e.g., MERV 12 or M6)
24–39 µg/m <sup>3</sup>	≥ 75% (e.g., MERV 14, F8 or ePM1 75%)
40 µg/m <sup>3</sup> or greater	≥ 95% (e.g., MERV 16, E10 or ePM1 95%)

A13 Enhanced Supply Air

☐

This project is designed to meet the parts selected below:

Part 1: Improve Supply Air

*All Spaces:*

*Cleaning and purification devices*

All regularly occupied spaces with recirculated air are treated with purification/cleaning system(s), either in the HVAC system or as a standalone device, which meet the following requirements:

☐

a. Use, at a minimum, two of the following air purification/cleaning technologies:

1. Activated carbon filter.
2. Media filter with an average removal efficiency of ≥75% for particles 0.3-1 µm in size (e.g., MERV 14; F8; ePM1 75%).
3. UVGI to treat the moving air OR upper-room UVGI.

☐

b. Comply with one of the following:

1. Are validated under UL 2998 Zero Ozone Emissions Validation or Intertek Zero Ozone Verification.<sup>15</sup>
2. Do not use electronic air cleaners.

☐

c. Are not designed to release ions, reactants, or other molecules into occupiable spaces to disinfect or clean the air.<sup>16</sup>

☐

d. Are sized appropriately to the room volume or area, based on manufacturer specifications.

☐

e. Are maintained according to the manufacturer’s recommendations. Documentation of maintenance is submitted annually through the WELL digital platform.

A14 Microbe and Mold Control

☐

This project is designed to meet the parts selected below:

Part 1: Implement Ultraviolet Treatment for HVAC Surfaces

*All Spaces:*



### UV system design

The following requirements are met:

- ☐ a. All central air handling units use ultraviolet lamps to irradiate the surfaces of the cooling coils and drain pans.<sup>10</sup>
- ☐ b. All cooling coils and drain pans not associated with central air handling units (e.g., those used in fan coil units or supplementary air handling units) either:
  - 1. Are irradiated by ultraviolet lamps.
  - 2. May be opened for inspection for mold growth and cleaned, if necessary.

Check	Water	Initials
	W07 Moisture Management	<input type="text"/>

This project is designed to meet the parts selected below:

### Part 2: Design Interiors for Moisture Management

*All Spaces:*

#### *Water leak control in fixtures*

The following requirements are met:

- ☐ a. All hard-piped fixtures, such as toilets, dishwashers, icemakers, water treatment devices and clothes washers, have a labeled, readily accessible single-throw manual shut-off or automatic shut-off at point-of-connection.
- ☐ b. For water treatment devices that have a waste or drain line (e.g., reverse osmosis systems and water softeners), the drain or waste line is plumbed in-place and is equipped with a backflow prevention system such as an air gap or a backflow preventer valve.

Check	Thermal Comfort	Initials
	T01 Thermal Performance	<input type="text"/>

This project is designed to meet the parts selected below:

### Part 1: Provide Acceptable Thermal Environment

*All Spaces except Commercial Kitchen Spaces:*

#### *Performance verified environmental conditions*

The following requirements are met, as applicable:

- ☐ a. Mechanically conditioned regularly occupied spaces maintain thermal comfort conditions of PMV +/- 0.5 for at least 90% of occupied hours in at least 90% of regularly occupied spaces.<sup>13</sup>

☐

b. Naturally conditioned regularly occupied spaces meet all the following conditions:<sup>12</sup>

	Prevailing Mean Outdoor Temperature, $t_{pma(out)}$	Indoor Operative Temperature	Notes
Minimum	50 °F	$t_{pma(out)} \times 0.31 + 47.9 \text{ °F}$	N/A
Maximum	92 °F	$t_{pma(out)} \times 0.31 + 60.5 \text{ °F}$	Occupant-controlled elevated air speed may be used to increase this maximum per ASHRAE 55

☐

c.

Mixed-mode-conditioned spaces meet the requirements for both mechanically and naturally conditioned spaces, when each is in operation

T04 Individual Thermal Control

☐

This project is designed to meet the parts selected below:

Part 1: Provide Personal Cooling Options

*All Spaces except Dwelling Units:*

The project provides all regular occupants with the ability to cool their individual environment through at least one of the following:<sup>1</sup>

☐

a. A user-adjustable thermostat, which controls the environment for no more than one person and is connected to the building's mechanical cooling system or a more localized air conditioning unit.

☐

b. A desk, standing, pedestal or ceiling fan that does not increase air speed for other occupants.

☐

c. Chair with mechanical cooling system.

☐

d. Any other solution capable of affecting a PMV change of -0.5 within 15 minutes from activation, without changing the PMV for other occupants.

Part 2: Provide Personal Heating Options

*All Spaces except Commercial Kitchen Spaces & Dwelling Units:*

The project provides all regular occupants with the ability to warm their individual environment through at least one of the following:<sup>1</sup>

☐

a. A user-adjustable thermostat, which controls the environment for no more than one person and is connected to the building's mechanical heating system.

☐

b. Electric parabolic space heater.

☐

c. Electric heated chair or footwarmers.

☐

d. Personal or shared blankets. Shared blankets are washed or disinfected at least weekly after use.

☐

e. Any other solution capable of affecting a PMV change of +0.5 within 15 minutes from activation, without changing PMV for other occupants.

T06 Thermal Comfort Monitoring

☐

This project is designed to meet the parts selected below:

Part 1: Monitor Thermal Environment

All Spaces:

Thermal comfort monitors

The following requirements are met:

☐

a. The project monitors dry-bulb temperature and relative humidity in occupiable spaces in compliance with the requirements outlined in the Continuous Monitoring Protocols of the Performance Verification Guidebook.

☐

b. The thermal comfort data monitored is made available to occupants through one of the following:

1. Display screens, with at least one screen located in each 5400 ft<sup>2</sup> zone of regularly occupied space.
2. A website or mobile application, with at least one sign located in each 5400 ft<sup>2</sup> zone of regularly occupied space, indicating where the data may be accessed.

☐

c. The thermal comfort data are updated at least once every 15 minutes.

T07 Humidity Control

☐

This project is designed to meet the parts selected below:

Part 1: Manage Relative Humidity

All Spaces:

Mechanical humidity control

The following requirement is met in all regularly occupied areas, except high-humidity areas:

☐

a. The mechanical system has the capability of maintaining relative humidity between 30% and 60% at all times by adding or removing moisture from the air.<sup>10,11</sup>

Check

Materials

Initials

X01 Material Restrictions

☐

This project is designed to meet the parts selected below:

Part 3: Restrict Lead

*All Spaces:*

*Drinking water pipes, fittings and solder*

Pipes, fixtures, fittings and solder newly installed or applied within the project boundary intended for drinking water distribution and delivery meet at least one of the following:

☐

a. The product is approved for use with drinking water by a local government authority or by a government-authorized certification body.

☐

b. The product has a weighted wetted average of 0.25% of lead or less, verified by a third party, or is labeled as ANSI/NSF 372-compliant.

By signing below, I represent that, to the best of my knowledge, all of the responses provided on this form are accurate and made in good faith.

Printed Name: \_\_\_\_\_

Signature: \_\_\_\_\_

If the individual using this form is not in the role of Engineer, provide a description of the individual's project role, including justification of their ability to sign off on the above requirements, here:

Project Role: \_\_\_\_\_

Explanation: \_\_\_\_\_  
\_\_\_\_\_